



# Certificate of Product Performance

## Residential Furnace Heating Equipment

**Certified Reference Number:** 952257

**Date Generated:** 10/15/09

**Status:** Approved

This certificate serves as verification that the model cited below has been rated in accordance with applicable federal testing methods and verified by AHRI as capable of achieving the energy efficiency and performance ratings as tested within prescribed tolerances. This

certificate and these certified ratings ONLY apply to the specific model detailed below and are non-transferable to alternate models or configurations.

<b>Manufacturer:</b>	GOODMAN MANUFACTURING COMPANY
<b>Model Number:</b>	GMV951155DX*
<b>Input Rating:</b>	115 MBTUH
<b>Output Heating Cap.:</b>	109 MBTUH
<b>AFUE:</b>	95.8 %
<b>Ef:</b>	95.4 MMBTU/yr
<b>Eae:</b>	397 kWh/yr
<b>PE:</b>	90 Watts
<b>Furnace Type:</b>	Non-Weatherized
<b>Configuration:</b>	Upflow, Horizontal
<b>Fuel Type:</b>	Natural Gas, Propane Gas

### Footnotes:

ECM MOTOR

"e" Electrically Efficient Furnace

### Additional Footnotes:

Variable speed, constant CFM blower.

May be installed as Non-Direct Vent (optional).

2 Stage Input

Suffix (\*) may be a letter or number

Certified ratings for ARI, GAMA, and I=B=R certification programs are valid only for models and configurations listed in the AHRI Directory of Certified Product Performance located at [www.ahridirectory.org](http://www.ahridirectory.org). The information for the model cited on this certificate can be located in the online directory by using the reference number on the certificate. AHRI does not endorse

the product(s) listed in this certificate and makes no representations, warranties or guarantees and assumes no responsibility for the product(s) listed in the certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s) or the unauthorized alteration of the data listed in this Certificate.

